

CENTURY A&E

Facilities Design

May 25, 2021

ADDENDUM NO. 2

City of Jonesville
265 E. Chicago Street
Jonesville, MI 49250

Century A&E Project No. CJN001

RE: Laboratory Renovations- Waste Water Treatment Plant

TO: **PROSPECTIVE BIDDERS:**

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated May 10, 2021. This addendum is to be initialed and submitted as part of each Bidder's bid package. Failure to do so may subject Bidder to disqualification. This Addendum No. 2 consists of one typed page, no revised contract drawings (not re-issued) and no revised specification sections.

REVISED SPECIFICATIONS

1. NA.

REVISED DRAWINGS

1. M1.1 Mechanical Schedules and Details (Not Reissued): "Roof Top Unit Schedule"- Revise voltage from 480 Volt, 3 Phase @ 15 FLA to 208 Volt, 3 Phase @ 22 FLA and 35 MOCP.

END OF ADDENDUM NO. 2

Respectfully submitted,

Century A&E

Craig C. Nicely, AIA
Project Manager

f:\projects\cjn001\pm\issued for\addenda\addendum no. 2- jonesville lab.docx

277 Crahen Avenue NE, Grand Rapids, Michigan 49525-3459
T 616.456.5227 F 616.456.5228 www.centuryae.com